

REQUEST FOR INFORMATION

PROJECT:
Our Lady of Victory-Parish Hall

Post-Bid RFI NO: 0011
 DATE OF ISSUANCE: May 13-16

OWNER:
Our Lady of Victory

ARCHITECT/DESIGNER:
Rawley McCoy & Associates

TO: Patrick Ohrt

PROJECT NO: 716-0114B

Please submit a response to the below indicated request/s for information in the form of an ASI, Proposal Request, and/or a qualified transmittal as dictated and/or necessitated by said response. An adequate response is requested within one (1) day/s after the receipt of the Request for Information by the designated party above to whom this communication was submitted or must notify the Contractor of the anticipated date on which a submission is anticipated. Should further information be required by the designated party to which the Request for Information is submitted, said party should contact the requestor within a reasonable frame of time so as not to cause an undue delay of further delay to construction.

ITEM/S:

1. There is a dimension missing on the metal canopy outside the Counseling Center. What is the size of the canopy?

ATTACHMENTS:

ISSUED BY:

Sharon Rose Fisher -Estimator
Lauger Companies, Inc.

RESPONSE:

ATTACHMENTS:

1. Width: 6'-0", refer to L5/BA2.1
 Length: 12'-5 1/4", refer to L5/BA2.1, field verify, columns to be centered on existing masonry pilasters
 Height: 8'-8", refer to A1/BA5.3

Issued By:



Authorized Signature

Patrick Ohrt

Printed Name / Title

05.16.16

Date Issued

END OF DOCUMENT